

102000 Interior Specialties

Sections Included In This Standard:

- 1.1 Access for Disabled Persons
- 1.2 Toilet Room Accessories
- 1.3 Toilet Compartments
- 1.4 Corner Guards

1.1 ACCESS FOR DISABLED PERSONS

All toilet accessories shall comply with the Florida Building Code, Chapter 11 Accessibility Code for Building Construction (Section 11-4.30).

1.2 TOILET ROOM ACCESSORIES

- A. GENERAL: Toilet accessories shall be surface mounted.
- B. MANUFACTURERS AND MODELS: The following are the replacement units used by the Physical Plant Division, they are the preferred models.
 - 1. Soap, Paper Towel, and Toilet Paper Dispensers: Soap, paper towel, and toilet paper dispensers are specified in the current PPD vendor contract for these items. Furnish PPD Building Services (Phone: 352-846-1622, Facsimile: 352-846-1623) with the required number of each type of unit and they will be supplied to the project at no cost.
 - 2. Waste Receptacle: Model B3644, manufactured by Bobrick.
 - 3. Handicap Tilt Mirror: Model B293, manufactured by Bobrick.
 - 4. Coat Hanger: Model B211, manufactured by Bobrick.

1.3 TOILET COMPARTMENTS

- A. ACCESS FOR DISABLED PERSONS: Refer to Appendix B – Access for Persons with Disabilities for information regarding accessible toilet stalls and rooms.
- B. TYPE: Toilet partitions shall be and urinal screens shall be 1" thick constructed from High Density Polyethylene (HDPE) resins. Painted metal, plastic laminate, or wood is not acceptable.
- C. CONSTRUCTION: Door edges shall be rounded to a radius. An aluminum heat sink shall be fastened to the bottom edges.
- D. HARDWARE: Hinges shall be integral, fabricated from the door and pilaster with no exposed metal parts. Door strike/keeper shall be made of heavy-duty extruded aluminum. Latch and housing shall be made of heavy-duty extruded aluminum. Pilaster shoes shall be 3" high and made of one-piece molded HDPE plastic. Wall brackets shall be made of extruded PVC plastic. Brackets shall be fastened to the pilaster with stainless steel tamper resistant torx head screws and fastened to the panels with stainless steel tamper resistant torx head screws

bolts. Headrail shall be made of heavy-duty extruded aluminum with anti-grip design and integrated curtain track.

E. INSTALLATION: Partitions shall be wall and floor mounted. Clearance at vertical edges of doors shall be uniform top to bottom and shall not exceed 3/8".

F. ACCEPTABLE MANUFACTURER: Santana.

1.4 **CORNER GUARDS**

A. Corner guards shall be required in all public spaces.

B. Corner guards shall be high-impact vinyl or stainless steel. Light gauge aluminum is not acceptable.

END OF SECTION