

212000 Fire Extinguishing Systems

Sections Included In This Standard:

- 1.1 General Requirements
- 1.2 Commercial Kitchens

1.1 GENERAL REQUIREMENTS

1. EH&S discourages the use of non-water-based fire suppression/extinguishing systems. Design engineers who believe such alternate systems are warranted for a particular space or building should arrange for a discussion with EH&S Fire Safety in the early stages of design.

1.2 COMMERCIAL KITCHENS

1. All new or renovated commercial kitchens with appliances shall be equipped with Ansul R-102 Liquid Agent Fire Suppression Systems with Overlapping Appliance Protection. Suppression systems are not required for residential applications.

END OF SECTION